

 **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No: F.6/DFS/MS/School/2024/WZ/ 168

Dated: 16/4/2024

To,  
The Principal,  
Horizon Model School,  
D- Block, Saraswati Vihar,  
Delhi-110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Adarsh Horizon Model School located at D-Block, Saraswati Vihar, Delhi- 110034.

Sir,

This has reference to your application received vide outdoor diary no. 14128 dated 12.03.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 02.04.2024 to see the compliance of the requisite fire safety measures. Sh. Himanshu Garg was present at the time of inspection.

During the course of inspection it was observed that the school is running on ground floor in a building comprised of Ground plus Two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Fire extinguishers not provided.
2. Electric meter and electrical panel installed near exit door has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

  
(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

