



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZ/ 170

Dated: 16/04/2024

To,
The Principal,
Adarsh Public School,
Village Harewali,
Delhi-110039.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Adarsh Public School located at Village Harewali, Delhi- 110039.

Sir,
This has reference to your application received vide email id dated 19.03.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 01.04.2024 to see the compliance of the requisite fire safety measures. Sh. Ravi Kant was present at the time of inspection.

During the course of inspection it was observed that previously this department had issued FSC for a building comprised of Ground floor only vide letter no. F6/DFS/MS/School/WZ/2021/344 dated 22/04/2021 but now the school building found comprised of Ground plus First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Width of staircase found 1.25 m against the required width of 1.50 m.
2. Fire extinguishers found provided but not functional.
3. Exit signages not provided.
4. Electric meter installed near the staircase has to be removed to a safer place.
5. Sanctioned building plan for addition of first floor is not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Atul Garg
9/4

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.