

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2024/161

Dated. 16.04.2024

To,

Sh. Vijay Bhardwaj,
Dy. Registrar,
Bharatiya Vidya Bhavan,
Mehta Sadan, K.G. Marg,
New Delhi - 110001.

**Sub: Regarding renewal FSC in r/o Bharatiya Vidya Bhavan, Mehta Sadan,
K.G. Marg, New Delhi - 110001.**

Sir,

This has reference to your letter No. Nil Dated 15/03/24 on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 01/04/24 in the presence of Sh. Vijay Bhardwaj, Dy. Registrar and the following shortcomings were observed:-

1. Smoke management found non-functional in the basement of high rise block.
2. Some fire extinguishers are due for refilling.
3. MOEFA found non-functional.
4. Hydrant coupling from hydrant system found removed at some places. Hoses are also not provided at hose boxes.
5. Exit signages found inadequate.

In view of above, the renewal of FSC cannot be considered at this stage. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :

1. Director of Education, Old Secretariat, New Delhi.