

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2024/SZ/197

Dated: 18/04/2024

To

The Authorised Signatory,
M/s Fashion Trendz,
S-40 Okhla Industrial Area,
Phase-II, New Delhi 110020

Sub.: Regarding grant of Fire Safety Certificate in r/o M/s Fashion Trendz at S-40 Okhla Industrial Area, Phase-II, New Delhi 110020

Sir,

This has reference to your letter received through Outdoor diary no 13068 dated 13/02/2024 on the subject above. In this connection, it is to inform you that the officer concerned of this department and observed the aforesaid building in presence of Mr. Ravi Kumar on 09/04/2024 to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check door not provided in building as approved by this department.
2. Overhead tank capacity 10,000 ltrs found provided against the required capacity 20,000 ltrs.
3. Temporary structure seen at terrace levels, which need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) MCD Jal Vihar, Lajpat Nagar, New Delhi 110024