



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2024/ 167

Dated: 16/07/2024

To,

Mr. Sanjay Tyagi (Estate Manager),
Government Girls Senior Secondary School
Manadoli Extension, Delhi - 110093.

Sub: - Regarding grant of Fire Safety Certificate in r/o Government Girls Senior Secondary School located at Manadoli Extension, Delhi - 110093.

Sir,

This has a reference to your email dated 04/03/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 05/01/2024 in the presence of Mr. Sanjay Tyagi (Estate Manager) and observed that building comprised of ground plus three Upper floors (New building).

Following shortcomings were observed during time of inspection:

1. Fire extinguishers not provided.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Government Girls Senior Secondary School located at Manadoli Extension, Delhi - 110093.