



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/FH/2024/SZ/ 189

Dated: 15/04/2024

To

Sh. Ashok Kumar Dusad,
M/s Krishna Greens By Mapple Gold,
H-1, Pushpanjali Farms, Dwarka Link Road,
Bharthal Road, Bijwasan, Delhi-110061

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Krishna Greens by Mapple Gold, H-1, Pushpanjali Farms, Dwarka Link Road, Bharthal Bijwasan, Delhi-110061

Sir,

Please refer to your online MHA ID No. 2024031803145 dated: 18/03/2024, on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 05/04/2024 with a view to adjudge the availability and operability of fire safety arrangements provided therein in the presence Mr. Bhupinder Jawa (Manager) & other staff and observed that there are additional structures construction in that premises. However, the shortcomings observed are as below.

1. The hose-reel provided found non-functional and without nozzle.
2. The MOEFA/MCPs provided found non-functional.
3. The PA System found non-functional.
4. The fire pumps provided were not on auto mode.
5. Exit signage found removed.
6. The sanctioned/regularized plans/drawings of additional structures (reception, offices, three nos. halls & kitchen at rear side & store at first floor etc.) constructed shall be provided through authority concerned for issuance of fire safety directives.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The concerned authority/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1st Floor, PS Defence Colony, New Delhi-110049
2. The Executive Engineer (Bldg.), MCD, Najafgarh Zone, Near Dhansa Stand, Najafgarh, New Delhi-110043