

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

19  
7  
आफ़ादीक  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/162

Dated: 16/04/2024

To

The Principal,  
New Sangam Convent School,  
G – 1312, Veer Bazar Road, Sangam Vihar,  
New Delhi-80.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s New Sangam Convent School, located at G – 1312, Veer Bazar Road, Sangam Vihar, New Delhi-80.

Sir,

This has reference to letter bearing outdoor diary no. 14242 dated 15.03.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 05.04.2024 in the presence of Mr. Anil (Manager) and it was observed that school building is comprised of Ground + 01 upper floor. During the inspection following shortcoming were observed:-

1. Alternate staircase having width not less than 0.75 meter is required.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.