

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NÖ. F-6/DFS/MS/Bldg/2024/SZ/ 202

Dated: - 19/04/2024

To
Mr. Vinay Sharma, (Director)
M/s Chiranjiv Tower, 43,
Nehru Place, New Delhi-110017

Sub: -Regarding issuance of fire safety certificate in r/o M/s Chiranjiv Tower, 43, Nehru Place, New Delhi-110019

Sir,
This has reference to your Email dated 29/03/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.04.2024 in the presence of Mr. Vinay Sharma to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door self closing device found removed at some place.
2. Smoke ventilation system provided but found nonfunctional.
3. First aid hose reel provided but found not functional.
4. Automatic detection system not provided in some of the cabins / compartments.
5. Sprinkler System provided but found not functional.
6. Internal hydrant provided but found nonfunctional.
7. Fire fighting pumps are not on auto mode and not integrated.
8. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE