

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2024/204

Dated: 19/04/2024

To

Sh. Amit Kain,
A2Z Infrservices Limited,
O-116, First Floor, DLF Shopping Mall,
DLF City, Phase-I, Arjun Marg,
Gurugram-122002.

**Sub:-Regarding renewal of Fire Safety Certificate in r/o E-2 Block, Civic Center,
J.L.N. Marg, New Delhi.**

Sir,

This has reference to your letter no. A2Z/INCOME TAX-CC/2024/FM-162 dated 13/03/24, on the subject cited above, in this connection it is to inform you that the site was inspected by the officers concerned of this department on 08/04/24 in the presence of Mr. Amit Kain & Sh. Vijay and the following shortcomings were observed:-

1. Some fire check door glass found broken and some are replaced with normal ply door.
2. Pressurization of staircases and lift lobby found nonfunctional.
3. Sprinkler flow switch panel is not provided at fire control room.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Dr. SPM, Civic Centre, JLN Marg, New Delhi.
2. The Commissioner of Income tax (CIT IT-2) cum building incharge, E-2 block Pratayksh Kar Bhawan, JLN Marg, New Delhi.