

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/Indl.2024/SZ/ 207
To

Dated: 19/04/2024

Mr. Kamal Sahdev,
M/s National Enterprises
Plot No 60, Okhla Industrial Area,
Phase-III New Delhi- 110020

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s National Enterprises at
Plot No 60, Okhla Industrial Area, Phase-III New Delhi- 110020

Sir,

This has reference to with letter no nil dated 06/02/2024, received through
Outdoor diary no 12785 dated 07/02/2024 on the subject above. In this connection,
it is to inform you that the premise was inspected by the concern nominated
authority of this department on 13/04/2024 in the presence of Mr. Anil Kumar to
check the compliance of fire safety arrangements from fire safety point of view and
following shortcomings were observed:

1. First aid hose reel provided but not functional
2. Automatic sprinkler system provided but not functional
3. Internal hydrant provided but not functional.
4. Terrace level pumps capacity 900 LPM provided but not functional.
5. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety
Certificate is rejected. The occupancy of the building/premises in absence of requisite
fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE