

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hospital/2024/SZ/201  
To

Dated 18/04/2024

Mr. Dileep Makhija,  
Nursing Home, (The Neptune Hospital)  
Plot No B-2/5, Safdarjung Enclave,  
New Delhi-110029

Sub: -Regarding renewal of Fire Safety Certificate in r/o Nursing Home in the name of "The Neptune Hospital" at Plot No B-2/5, Safdarjung Enclave, New Delhi-110029

Sir,

This has reference with letter received through outdoor diary no 14511 dated 22/03/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.04.2024 to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 One of the staircase widths is now measured 1.40 mtr due to fixing of skirting /hand rails and wall paneling.
- 2 First aid hose reel provided but found nonfunctional.
- 3 Automatic Sprinkler system provided but found nonfunctional.
- 4 Internal hydrant provided but found nonfunctional.
- 5 Fire fighting pumps are not on auto mode.
- 6 Exit signage found removed at some places.
- 7 Temporary structure at terrace level is not allowed as per UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer Bldg Department, Green Park Zone, New Delhi 110016