

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2024/SZ/ 208
To

Dated: 19.04.2024

Mr. Executive Engineer (Bldg) HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi 110002

Sub: Regarding issuance of FSC in r/o M/s Plot No G-2, Hauz Khas Enclave, New Delhi

Sir,

This has reference to with **online ID 10102125 dated 08/04/2024** on the subject cited above. In this connection, this is to inform you that joint inspection of the premise was conducted by the team of officers from Delhi Fire Service on 16.04.2024 in the presence of Mr. Jay Shankar JE (Bldg) MCD to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The fire check door exit width is 1.1 mtr against the required width of 1.50 mtr.
2. The Sealing of shafts not done.
3. Ventilation system not provided.
4. Exit Signage not provided.
5. Standby power supply not provided.

The same observations has already been issued and communicated earlier by this department vide letter of even no 19 dated 25/01/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]