

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Business/2024/SZ/203
To,

Dated: 19/04/2024

The Authorized Signatory,
Punj Lloyd House, 17-18 Nehru Place,
New Delhi-110019

Sub: Regarding renewal of Fire Safety Certificate in r/o Punj Lloyd House, 17-18
Nehru Place, New Delhi-110019.
Sir,

This is in reference with your Email Dated 27/03/2024 on the subject cited above. In this connection, this is to inform you that the premise was inspected by the concern nominated authority of this department on 13/04/2024 in the presence of Mr. Raman Singh (Manager) to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system provided but found nonfunctional.
2. First aid hose reel provided but found nonfunctional.
3. Internal hydrant provided but found nonfunctional.
4. Terrace level pumps capacity 1080 LPM provided but not functional.
5. Exit Signage found removed.
6. Temporary structure at terrace level is not allowed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 1607 dated 02/08/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Bldg.), MCD, Jal Vihar, Lajpat Nagar, New Delhi-110024