



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजगदी ७५
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / 2024/209

Dated: 22/04/2024

To,

The Medical Superintendent,
Shakuntla Nursing Home & Hospital,
RZ-I-81A, Sagar Pur (West),
(Opp. Delhi Vidyut Board Colony),
New Delhi-110046.

Sir,

Please refer your letter No. Nil dated 26.02.2024. In this connection it is to inform you that the as-built plan, submitted by you, has been examined from fire safety point of view and observed following shortcomings:

1. Staircases, serving form basement, are not segregated on ground floor.
2. Width of corridor is not in accordance with UBBL – 2016.
3. Transformer room is not segregated with 4-hour rating wall / door.
4. Exits are violating the clause 7.5.10 of UBBL – 2016 in basement.
5. Width of doors in ward is not meeting the requirement of clause 7.12 of UBBL -2016.
6. One staircase is not continuous to terrace.
7. Opening of doors at terrace is not in accordance with clause 7.12 of UBBL- 2016.
8. Fire Check Doors are not marked in OT & ICU as per NBC- Part-4-2016.

Therefore, plan is returned to you in original with request to rectify the above shortcomings and re-submit the proposal for further consideration in the matter.

Yours faithfully


Encl.: As stated above


19/4/24

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

011-23412025



Copy to:

The Medical Superintendent, Nursing Homes,
Directorate General of Health Services,
Govt. of NCT of Delhi (Nursing Home Cell),
3rd Floor, Delhi Government Dispensary Building,
S-1, School Block, Shakarpur, Delhi – 110092.