



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/2/24  
आपत्ती का  
अमृत महोत्सव

19

No.F6/DFS/MS/School/SZ/2024/ 163

Dated: 16/04/2024

To

The Principal,  
Saraswati Shiksha Niketan,  
J-2-49/2, Gupta Colony, Sangam Vihar,  
New Delhi-80.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **Saraswati Shiksha Niketan located at J-2-49/2, Gupta Colony, Sangam Vihar, New Delhi-80.**

Sir,

This has reference to letter bearing outdoor diary no. 14261 dated 15.03.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 08.04.2024 in the presence of Mr. Dhyan Singh (Manager) and it was observed that school is running on Ground + 1 upper floor of the building which is comprised of Ground + 02 upper floors (2<sup>nd</sup> floor is being used as owner's residence). During the inspection following shortcoming were observed:-

1. Alternate staircase having width not less than 0.75 meter is required.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

09/4/24

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.