



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F-6/DFS/MS/2024/Indl./ 194

Dated: 18/04/2024

To,

The Authorized Signatory
Sharp Mint Ltd. at C-3, SMA, Co-Operative,
G.T. Karnal, Industrial Area, Delhi-110033.

Sub: Regarding issuance of Fire Safety Certificate in r/o Sharp Mint Limited located at C-3, SMA, Co-Operative, G.T. Karnal, Industrial Area, Delhi-110033.

Sir,

Please refer to your letter No. nil dated 01.04.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 12.04.2024 in the presence of Sh. Mukesh Yadav (Attendant) to verify the status of the shortcomings already issued by this department vide letter No. F6/DFS/MS/2024/Indl./153 dated 25.01.2024 and status is as under: -

S No.	Shortcomings	Status
1.	There are two staircases provided width of 1.20m each against the requirements of 1.50m each and both staircases required from ground to terrace level.	Provided
2.	Fire check doors not provided.	Not Complied
3.	The doors size of 01m provided against the requirements of 1.50m in staircase.	Not Complied
4.	Smoke ventilation system is not provided in the building.	Provided
5.	Hose reel hose is provided but not functional	Provided
6.	Smoke detector is not provided.	Provided
7.	Manually operative fire alarm system is provided but not functional.	Provided
8.	Sprinkler systems is not provided at 1 st floor & 2 nd floor in the building.	Not Complied
9.	Internal hydrant & yard hydrant is provided but not functional.	Provided
10.	Terrace level fire pump capacity of 900 lpm is provided but found not functional.	Provided
11.	Terrace level fire water tank capacity of 10,000ltr is provided against the requirement of 50,000ltr.	Not Complied
12.	Exit signage's and floor signage is not provided at strategic location in the building.	Provided

Keeping in view of above observations, the said building is not safe from fire safety point of view. Hence, you are hereby advised to comply the observations at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non-compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(A. Garg)
Director

Ph:-011-23414000