

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/Metro/2024/ 205

Dated: 19/04/2024

To,

Sh. Malay Saha (CGM/E&M),
Metro Bhawan, 13, Fire Brigade Lane,
Barakhamba Road, New Delhi-110001.

**Sub:-Regarding renewal of Fire Safety Certificate in r/o Shivaji Stadium Underground
Metro Station (Airport Line) New Delhi.**

Sir,

This has reference to your letter no. **DMRC/O&M/FIRE/NOC/L-AEL/2024/01** dated **13.03.2024**, on the subject cited above, in this connection it is to inform you that the site was inspected by the officers concerned of this department on 08/04/24 in the presence of Sh. Ravinder (Fire Officer) & Sh. Omkara, AM and the following shortcomings were observed:-

1. Horizontal openings are not sealed at some places.
2. Smoke management system found nonfunctional.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Sang)
DIRECTOR
Delhi Fire Service