



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 165

Dated: 16/04/2024

To

The Principal
Sunmax Public School,
A-Block, Pradhan Enclave,
Burari, Delhi-110084.

Sub: - Regarding grant of fire safety certificate in r/o Sunmax Public School located at A-Block, Pradhan Enclave, Burari, Delhi-110084

Sir,

Please refer to your online e-mail dated 01.04.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02.04.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors fall under the ambit of Rules 27 of DFS Act 2007 & Rules 2010. Mrs. Tanushri Singh (Principal) was also present at site at the time of inspection. During the course of inspection the following were observed:-

1. Two staircase are provided having width of 90cm & 85cm against the requirements of 1.50m each.
2. The classroom doors size is 01m against the requirements of 1.20m.
3. Hose reel hose is not provided.
4. MOEFA system is not provided.
5. Terrace level fire pumps capacity 450lpm is not provided.
6. Terrace level fire water tank capacity 10,000ltr is not provided.
7. Exit signage's is not provided at strategic location in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23474000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.