

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Dated 12/04/2024

NO. F-6/DFS/MS/GH/2024/SZ/153

To

The Joint Commissioner of Police
Lic. / Branch, 1st floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s V. M. Residency Guest House located at 50, Main Road, Massood Pur, New Delhi 110070

Sir,

This has reference to with **MHA Portal ID 2023041005947 Dated 12.03.2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.04.2024 in the presence of Mr. Sulekh Malik to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. Smoke Management system not provided in the building as per clause 7.31 of UBBL 2016.
2. First aid hose reel provided but found non-functional.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
4. Terrace level fire fighting pumps capacity 450 LPM provided but found non-functional.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE