

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2024/ 175

Dated: - 18/04/2024

To,

The Principal,  
Adarsh Model School,  
RZ-13, 14, 15 & 16, Dayal Sar Road,  
Uttam Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Adarsh Model School, RZ-13, 14, 15 & 16, Dayal Sar Road, Uttam Nagar, New Delhi-110059.

Sir,

With reference to your letter No. Nil, dated 15.03.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 02.04.2024 in the presence of Sh. Ashwani Kumar (Manager), to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of ground floor plus three upper floors. Fire safety arrangements such as hose reel, fire extinguishers etc. found provided in the school building. However, the following shortcomings were observed: -

1. Two permanent rooms and temporary structure made at fourth floor should be removed.
2. First aid hose reel provided at each floor but found not functional.
3. Terrace fire pump capacity of 450 LPM & 180 LPM found provided but not functional in auto mode.
4. Exit signage found not provided.

In view of the above, renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

ole  
:-for information please.