

c/73

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 172

Dated: 18 / 04 / 2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Ashirwad Guest House, Plot No. 72, Bagh Diwar, Fatehpuri, Delhi-06.

Sir,

This is in reference to online application I.D. no. 2024032803714 dated 28.03.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 10.04.2024 in the presence Mr. Bacchan Singh (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors which are required as per gazette notification dated 27.05.2019, not provided.
2. CO detectors with panel and alarm which are required as per gazette notification dated 27.05.2019, not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service 01  
Tel: 011-23414000  
20/04/24

**Copy to:-**

The Licensee,  
M/s Ashirwad Guest House, Plot No. 72, Bagh Diwar, Fatehpuri, Delhi-06.