

c/92

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/CH) 175

DATED: 19/04/2024

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/s Classic Guest House Located at 17A/59, WEA, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024032203461, dated 28/03/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 13/04/2024 in the presence of Sh. Jitender Chadha from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. PA system found nonfunctional.
2. Terrace pump found nonfunctional on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)  
Director,  
Delhi Fire Service

Copy to:-

1. The Manager, M/s Classic Guest House Located at 17A/59, WEA, Karol Bagh, New Delhi - 110005.