

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

C-8

No.F6/DFS/MS/School/NDZ/2024/ 173

Dated: 18 104 /2024

To

The President,
Dau Dayal Arya Vedic Senior Secondary School,
Naya Bans, Khari Baoli, Delhi - 110006.

Sub:- Regarding issuance of Fire Safety Certificate (FSC) in r/o **Dau Dayal Arya Vedic Senior Secondary School at 6053-54, Naya Bans, Khari Baoli, Delhi - 110006.**

Sir,

This has reference to letter outdoor diary no. 13497 dated 23.02.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned of this department on 02.04.2024 in the presence of Dr. Achal Sharma (Principal) and it was observed that building is comprised of ground + mezzanine + 05 upper floors. During the inspection, following shortcomings were observed:-

1. Compartmentation not provided.
2. First aid hose reels not provided.
3. MOEFA not provided.
4. PA system not provided.
5. Automatic sprinkler system not provided.
6. Wet riser down comer system not provided.
7. Fire pump at terrace level not provided.
8. Overhead water storage tank not provided.
9. Alternate source of electric supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.