

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/ 138

Dated: 16/04/2024

To

The Dy. Health Officer, MCD,
Public Health Department, Central Zone,
Lajpat Nager, New Delhi 110024.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s F ONE CAFÉ (A unit of Shivam Hospitality) at F-1. Second Floor, Kalkaji, New Delhi 110019

Sir,

This has reference with **MHA Portal ID 2024032003316** dated **20-03-2024** & **MHA Portal ID 2024031903248** dated **19/03/2024** on the subject cited above. In this concerned, it is to inform you that the premise was inspected by the concern nominated authority of this department on 10/04/2024 in presence of Mr. Lala Ram Verma to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, Ground + Three upper floor but restaurant running at Second Floor only. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two exit door having width of 1.50 mtr & 1 mtr against the required width of 1.50 mtr each.
2. First aid hose reel provided but found nonfunctional.
3. Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
4. Dedicated terrace level fire fighting pump 450 LPM not provided.
5. Underground tank capacity 1, 00,000 ltrs not provided.
6. Dedicated Overhead tank capacity 10,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st floor PS Defence colony, New Delhi -49