



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F6/DFS/MS/WZ/EH/2024/139

Dated: 19/04/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s. Firangi Grill located at Plot No. 62, GF, Rama Road, Najafgarh Road, New Delhi-15.

Sir,

This is in reference to the online application received through MHA portal vide ID-Online ID 2023052009295 dated – 26/03/2024 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 10/04/2024 in the presence Sh. Ankur Aggarwal to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said restaurant is running at Ground floor in a building comprised Ground floor. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, MOEFA, Overhead tank & Terrace Pump etc provided. However the following shortcomings were observed.

1. First Aid Hose Reel & Internal Hydrant is provided but not functional.
2. MOEFA is provided but not functional.
3. Terrace level pump capacity of 450 LPM is provided but not on auto mode.
4. Overhead tank capacity of 20000 ltrs is provided but found empty.
5. Exit signage's found removed.

In view of above Shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)  
Director

*[Handwritten signature]*  
19/4/2024

Copy to: -

1. The Dy. Health Officer, MCD, Karol Bagh Zone, North Delhi, Room No. 406, New Delhi- 110027.
2. The Owner/ Occupier M/s. Firangi Grill located at Plot No. 62, GF, Rama Road, Najafgarh Road, New Delhi-110015