

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

C-109

No. F6/DFS/MS/GH/NDZ/2024/ 168

Dated: 16 10 2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/S Five Star Guest House located at 3631, Netaji Subhash Marg, Darya Ganj, Delhi.

Sir,

This has reference to your online application I.D. no. 2024032903784 dated 29.03.2024 on the subject cited above. In this connection, it is informed that the guest house was inspected by the officer concerned from this department on 09.04.2024 in the presence Mohd. Tahir Ali (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcoming was observed:

1. CO detectors with panel and alarm system which are required as per gazette notification dated 27.05.2019, not provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Manager,

M/S Five Star Guest House at 3631, Netaji Subhash Marg, Darya Ganj, Delhi.

o/c
17/4/24