

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/College/2024/WZ/ 66

Dated: 18/04/2024

To,

The Principal,
Keshav Mahavidyalaya,
Plot No. H- 4/5, Road No. 42, 43,
Pitampura, Delhi-110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Keshav Mahavidyalaya located at Plot No. H- 4/5, Road No. 42, 43, Pitampura, Delhi- 110034.

Sir,

This has reference to your application received vide outdoor diary no. 13331 dated 20.02.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said college building has been carried out by officer concerned of this department on 04.04.2024 to see the compliance of the requisite fire safety measures. Sh. Raj Kumar Yadav (P.A. to Principal) & Sh. Tranjay (J.E. N/W Elect. Div. P.W.D.) were present at the time of inspection. Previously this department had issued FSC for college building except auditorium vide letter no. F6/MS/DFS/2006/1149 Dated- 19/05/2006.

During the course of inspection it was observed that the college building is comprised of Ground plus Two upper floors & auditorium. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels provided but not functional.
2. Internal Hydrant provided but not functional.
3. Pumping system not found in automation.
4. Terrace level pump of 450 lpm capacity found not provided.
5. Inspection ladder not provided.
6. Exit signage's not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Executive Engineer, Electrical, N/W Elect. Div., PWD, Kashmiri Gate, Delhi..