

C/179

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/GH/2024/SZ/ 140

Dated: 19/04/2024

To,

The Joint C.P. (LIC.),  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M/s Om Sweets Pvt. Ltd., GL-23, Shaheed Bhagat Singh Marg, Jail Road, Hari Nagar, New Delhi-64.

Sir,

2024030102378 ✓

Please refer to your letter ID No. 2022041507107 dated 20.03.2024, on the subject cited above. In this connection this is to inform you that the eating house building have been inspected by the officers concerned of this department from safety point of view on 15.04.2024 in presence of Mr. Azeem (Manager), and observed that the building is comprised of Basement, ground plus three upper floors but the restaurant running at first floor only and have following shortcomings: -

1. First aid hose reel found provided but not functional.
2. Internal hydrant system found provided but not functional.
3. Underground and terrace level fire pumps found provided but not functional.
4. Exit signage's found removed.
5. Building plan attached with application is not matching with the actual building plan, Please submit as built building plan.


Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

  
(Anil Garg)

Director

Delhi Fire Service



Copy to:-

The Owner/occupier, M/s Om Sweets Pvt. Ltd., GL-23, Shaheed Bhagat Singh Marg, Jail Road, Hari Nagar, New Delhi-110064.