

0/127

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 169

Dated: 18/04 /2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding issue of Fire Safety Certificate in respect of **M/s Rajdhani Guest House located at 465-466, Esplanade Road, Chandni Chowk, Delhi.**

Sir,

This has reference to online application I.D. no. 2024032803731 dated 28.03.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 09.04.2024 in the presence of Mohd. Irshad Alam (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. CO detectors found not functional.
2. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service 012
Tel: 011-23414000

Copy to:-

The Licensee, M/s Rajdhani Guest House at 465-466, Esplanade Road, Chandni Chowk, Delhi.

02
14/4
17/4