

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 177

Dated: - 18/04/2024

To,

The Principal,
Sai Kids Play School,
S-53, Near Gandhi Chock, Mohan Garden Ext.,
Uttam Nagar, New Delhi- 110027.

Sub.: - Regarding issuance of Fire Safety Certificate in r/o Sai Kids Play School at A-5, S-53, Near Gandhi Chock, Mohan Garden Ext., Uttam Nagar, New Delhi- 110059.

Sir,

With reference to your letter No. S.K.P.S/D.F.S/2024 dated 27.03.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 05.04.2024 in the presence of Mr. Rakesh Sharma (Principal), to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of ground floor plus two upper floors. Fire safety arrangements such as fire extinguishers found provided in the school building. However, the following shortcomings were observed: -

1. One staircases having width of 1.0 mts found provided against requirement of two staircase having width of 1.50 mts each.
2. First aid hose reel 01 Nos. at each floor found not provided.
3. Terrace fire pump capacity of 450 LPM found not provided.
4. Overhead water storage tank capacity of 10,000 lts found not provided.
- 5: Exit signage and floor marking at fire escape point found not provided.

In view of the above, issuance of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further necessary action in the matter.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.

For information please.