

C/75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2024/ 166

Dated 16/04/2024

To,

The Manager,
Shree Guru, Guest House,
XV/857, Mohalla Mantola Gali Chandi Wali,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o Shree Guru, Guest House, XV/857, Mohalla Mantola Gali Chandi Wali, Pahar Ganj, New Delhi.

Sir,

This has reference to your online id no. 2024032403559 dated 24.03.2024, on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 04/04/2024 in the presence of **Manager** and the following shortcomings were observed:-

1. Hose reel found nonfunctional.
2. Overhead tank & pump found removed as repairing/maintenance works is undergoing in the guest house.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.