

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/ 215

Dated: 24/04/2024

To

The Authorized Signatory,
Ansal Tower, Plot No 38,
Flat owners Welfare Association,
New Delhi 110019

Sub: Regarding issuance of FSC in r/o M/s Ansal Tower at Plot No 38, Nehru Place,
New Delhi 110019.

Sir,

This has reference to your letter no nil dated 21/03/2024, received through outdoor diary no 14521 dated 22/03/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 18.04.2024 in the presence of Mr. Kuldeep Rana (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Fire Check Doors needs to be repaired / replaced in the building.
2. The Sealing of Shafts not done.
3. Automatic Detection system not provided in the flats.
4. Fire fighting pumps not on auto mode.
5. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg Department) MCD Civic Centre, New Delhi 110002