



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2024 | 183

Dated: 23/04/2024

103

To

The Principal,
M/s Brainbells Public School,
H-16/1489, Near Shiv Mandir,
Sangam Vihar, New Delhi.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Brainbells Public School located at H-16/1489, Near Shiv Mandir, Sangam Vihar, New Delhi.

Sir,

With reference to letter bearing outdoor diary no. 13949 dated 06.03.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.04.2024 in the presence of Mr. Ashish Khawal (Principal) and it was observed that the building is comprised of Lower Ground + Ground + 1 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters each not provided in the building.
2. Six nos. of Fire Extinguishers found not provided.
3. First aid hose reels found not provided.
4. Fire pump found not provided.
5. Terrace water tank of 10,000 liters found not provided (exclusively for firefighting).
6. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.