



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/33
DEPT. OF FIRE SERVICE
GOVT. OF NCT OF DELHI

No: F.6/DFS/MS/School/2024/WZ/ 181

Dated: 23/04/2024

To,

The Principal,
Chetan International School,
Krishna Colony, Singhu Border Road,
Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Chetan International School located at Krishna Colony, Singhu Border Road, Narela, Delhi- 110040.

Sir,

This has reference to your application no. C.I.S./D.F.S./2024-03 received through outdoor diary no. 14640 dated 27.03.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 05.04.2024 to see the compliance of the requisite fire safety measures. Mrs Jyoti (In-charge) was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground floor only. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. The school building is not accessible to fire engine, the road width found 4.5 m against the required width of 6 m.
2. Fire extinguishers not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Atul Garg

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.