

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2024/SZ/ 219

Dated:- 25/04/2024

To

Mr. R. K Kaswan, Dy. GM (Engg.)
NSC Limited, Beej Bhawan, Pusa Complex,
New Delhi 110012.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Farm Bhawan at 14-15,
Nehru Place, New Delhi

Sir,

This has reference to with letter no 16(8)/NSC-ENGG/FARM BHAWAN/FIRE
NOC/23-24 dated 02/04/2024 on the subject cited above. In this connection, it is to
inform you that the above mentioned premise was visited by the officer concerned of this
department on 18.04.2024 in the presence of Mr. Prem Kumar Deshwal (Care taker) to
verify the fire safety measures installed in the building. During inspection, following
points were observed:

1. Fire Check door found removed.
2. First aid hose reel nozzle found removed.
3. Fire fighting pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate
is rejected. The occupancy of the building/premises in absence of requisite fire safety
arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE