



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/31  
75  
आज़ादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024 | 184

Dated: 23/04/2024

To

The Principal,  
M/s Kalawati Public School,  
B-98/27, Jaitpur, Near Gyan Mandir Road,  
Badarpur, New Delhi-44.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Kalawati Public School located at B-98/27, Jaitpur, Near Gyan Mandir Road, Badarpur, New Delhi-44.

Sir,

This has reference to letter bearing outdoor diary no. 13976 dated 07.03.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 15.04.2024 in the presence of Mr. Tarun Chauhan (Manager) and it was observed that school building is comprised of Ground + 02 upper floors. During the inspection following shortcoming were observed:-

1. Downcomer for Hose reel is not as per standards.
2. Fire pump of 450 LPM discharge not provided.
3. Overhead tank of 10,000 liters capacity not provided.
4. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.