

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 25/04/2024

No. F.6/DFS/MS/2024/SZ/ 217

To

(S. P Sanwal) Dy. GM (Admin)
National Highways & infrastructure development corporation Ltd,
3rd Floor PTI Building, 4- Parliament street New Delhi 110001

Sub: Regarding issuance of NOC in r/o Office Space of NHIDCL at A-100 & A-200, 1st & 2nd floor, Tower A, WTC Nauroji Nagar, New, Delhi

Sir,

This has reference to your letter NHIDCL/Admin/Officerbuilding/WTC/2022/e-212671 dated 02/04/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 12.04.2024 in the presence of Mr. Aditya Kumar (IT Engineer) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke Management system not provided and it shall be integrated with building fire alarming system.
2. Detection / system not integrated with existing building fire fighting control panels.
3. MOEFA not integrated with existing building fire fighting control panels
4. Exit Signage's not provided.
5. The wooden wall panelling needs to be painted with fire retardant pain of having 2 hrs fire rated

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. Mr. Sasi Kumar M. (Chief General Manger) Redevelopment of Nauroji Nagar, New, Delhi