

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2024/SZ/ 218

Dated: 25/04/2024

To

Arumugarangarajan P, (Chief General Manager (Admin)
Pension Fund Regulatory and Development Authority,
B-14/A, Chatrapati Shivaji Bhawan,
Katwaria Sarai New Delhi 110016.

Sub: Regarding issuance of NOC in r/o Office Space of PFRDA located at E-500, 5th floor,
Tower E, WTC Nauroji Nagar, New, Delhi

Sir,

This has reference to your letter no PFRDA/06/12/11/0001/2022-Admin-Part(1) dated 19/02/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 12.04.2024 in the presence of Mr. Abhishek (Site IC) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke Management system not provided and it shall be integrated with building fire alarming system.
2. Detection / system not integrated with existing building fire fighting control panels.
3. MOEFA not integrated with existing building fire fighting control panels
4. Exit Signage's not provided.
5. The wooden wall panelling needs to be painted with fire retardant pain of having 2 hrs fire rated.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

W