

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/ 220
To

Dated: 25/04/2024

For Lakshmikumaran & Sridharan,
5, Link Road, Jangpura Extension,
New Delhi 110014.

Sub: Regarding issuance of NOC in r/o M/s Office Space of **Unit Nos E-600 & E-700 on the 6th & 7th floors Tower E**, WTC Nauroji Nagar, Delhi

Sir,

This has reference to your letter no Email dated 30/03/2024 & letter dated 01/04/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 12.04.2024 in the presence of Mr. Abhishek (Site IC) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The width of exit at cafet is 75 cm again the required width of 1.50 mtr.
2. Smoke Management system not provided and it shall be integrated with building fire alarming system.
3. Detection / system not integrated with existing building fire fighting control panels.
4. MOEFA not integrated with existing building fire fighting control panels
5. Exit Signage's not provided.
6. The wooden wall panelling needs to be painted with fire retardant pain of having 2 hrs fire rated

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE