

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2024/SZ/ 221

Dated: 25.04.2024

To

The Authorized Signatory,
VSNL/TCIL Bhawan at Wireless Complex,
Greater Kailash-I, New Delhi 110048

Sub: Regarding issuance of FSC in r/o VSNL/TCIL Bhawan at Wireless Complex,
Greater Kailash-I, New Delhi 110048

Sir,

This has reference to your Email dated 02/02/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 18.04.2024 in the presence of Mr. Mukund Sinha to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. 06 mtr width internal roads found encroached.
2. One staircase found under lock and key which need to be easily accessible to all occupant in case of emergency.
3. The Fire Check door found removed at some places.
4. Smoke management system found removed in the building.
5. Automatic Detection system provided but found not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to :-

1. The Executive Engineer (Bldg) MCD, Green Park zone New Delhi 110016