



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/3

No: F.6/DFS/MS/School/2024/WZ/ 185

Dated: 23/04/2024

To,

The Principal,
Credence Global School,
33/16 & 17, Gali No. 13, Sanjay Colony,
Main Safiyabad Road, Narela,
Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Credence Global School located at 33/16 & 17, Gali No. 13, Sanjay Colony, Main Safiyabad Road, Narela, Delhi- 110040.

Sir,

This has reference to your email id dated 27/03/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 05.04.2024 to see the compliance of the requisite fire safety measures. Ms Jyotika (Admin. Head) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and three upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. There is only one staircase having width 1.10 m provided against the requirement of 2 staircases of width 1.5 m each and both the staircases should reach up to terrace.
2. Class room door width found 0.95 m against the required width of 1.20 m.
3. First Aid Hose Reel found not provided.
4. Terrace level pump of 450 lpm capacity not provided.
5. Overhead tank of 10,000 ltrs found not provided.
6. Exit signage's found not provided.
7. Sanctioned Building plan not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.

15/4