



c/20



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/WZ/2024/ EN/176

Dated:- 19/04/2024

To,

Sh. Baboo Walia,  
M/s. Vardaan Sandoz BBQ  
A Unit of JB Decore Pvt. Ltd.,  
Hall No. 2, Dilli Haat, Pitampura,  
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Vardaan Sandoz BBQ (A Unit of JB Decore Private Limited) located at Hall No. 2, Dilli Haat, Pitampura, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024032003288 dated 20.03.2024 on the subject cited above. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department on 15.04.2024 in presence of Sh. Baboo Walia to check the fire safety measures provided in the building.

During the course of inspection it has been observed that the restaurant is running at ground floor only. Fire safety arrangements such as fire extinguishers, hose reels, hydrants etc found provided, However the following shortcomings have been observed:-

- 1 First Aid Hose reel provided but not functional.
- 2 Internal Hydrant provided but not functional.
- 3 Terrace pump not found in auto mode.
- 4 Exit signage's not provided.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully,

(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024032003288.