

e73

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/college/77

Dated: 26/04/2024

To,

Dr. Tarannum Ahmad.
Shaheed Sukhdev College of Business Studies,
PSP Area IV, Dr. K. N. Katju Marg, Sector-16,
Delhi-110089.

Sub: Issue of FSC in r/o Shaheed Sukhdev College of Business Studies, PSP Area IV, Dr. K. N. Katju Marg, Sector-16, Delhi-110089..

Sir,

Please refer your office letter No. SSCBS/OFFICE/2023-24/1504 dated 21.02.2024, received in this department vide O.D No. 13726 on dated 29.02.2024 on subject cited above. The premise was inspected by the concern nominated authority of this department on 16.04.2024, in presence of **Sh. Tranjay (J.E Electrical) PWD & Sh. Jagan (Caretaker)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Pressurization system provided but neither functional nor interlinked with detection system.
2. Smoke management system provided but neither functional in auditorium nor interlinked with detection system.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully

(Abul Garg)
DIRECTOR

Ph; 011-23414000

On
04