

25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ 94 | 181

DATED: 25/04/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/s Hotel Singh Sahib Located at 8/34, WEA, Satbhrawn School Road, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024012900954, dated 29/02/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 19/04/2024 in the presence of Sh. Lokinder Singh from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire check doors found not provided.
2. Smoke exhaust system found nonfunctional/ inadequate.
3. Hose reel hose system found nonfunctional
4. MOEFA & PA system found nonfunctional.
5. Terrace pump found nonfunctional and main valve found closed.
6. Electric panel found installed in staircases.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Manager, M/s Hotel Singh Sahib Located at 8/34, WEA, Satbhrawn School Road, Karol Bagh, New Delhi - 110005.