

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

2/70

No. F6/DFS/MS/EH/WZ/2024/155

Dated: 25/04/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

**Subject: Regarding renewal of NOC from fire safety point of view in respect of M/s Imly (A unit of Flashbolt Café Pvt. Ltd.) located at Property No. 3, Ground floor, Vaishali Enclave, New Delhi-110088.**

Sir,

Please refer to your online application no. 2024030902786 dated 27/03/2024 on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by the officer concerned of this department on 15/04/2024 in the presence of Sh. Alok Singh to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor in a building comprised of Basement, Ground plus three upper floors. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Internal Hydrant etc provided. However the following shortcomings were observed.

1. Alternate exit door is found blocked.
2. First-Aid Hose Reel & Internal Hydrant is provided but not functional.
3. Terrace Level pump capacity of 900 LPM provided but not functional.
4. Overhead tank capacity of 20,000ltr is provided but found empty.

In view of above Shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier, M/s Imly (A unit of Flashbolt Café Pvt. Ltd.) located at Property No. 3, Ground floor, Vaishali Enclave, New Delhi-110088.
2. The DHO, MCD, Keshav Puram Zone, Public Health Department, A- Block, Keshav Puram, New Delhi.

*[Handwritten signatures and initials]*  
18/4/2024