

Dated: 25/04/2024

No. F6/DFS/MS/BNQT/NDZ/2024/ 62

To,

The Manager,
S.K. East End Part Hall
Plot no. 1/A, Ground floor level,
Star City Mall, Mayur Vihar Phase -1,
Delhi -110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s S.K. East End Part Hall located at Plot no. 1/A, Ground floor level, Star City Mall, Mayur Vihar Phase -1, Delhi - 110092.

Sir,

This has a reference to your MHA Portal application No. 2024030902794 dated 27/03/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/04/2024 in the presence of Mr. Satish Kapoor (Owner) and observed that building comprised of basement, ground plus two upper floors but banquet hall running on Ground floor only.

Following shortcomings were observed during time of inspection:

1. Fire check doors not provided.
2. First-Aid-Hose Reels provided but not functional.
3. MOEFA is provided but not functional.
4. Internal Hydrants provided but not functional.
5. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Mr. Satish Kapoor, M/s S.K. East End Part Hall located at Plot no. 1/A, Ground floor level, Star City Mall, Mayur Vihar Phase -1, Delhi - 110092.
2. The Joint Commissioner of police (Lic), 1st Floor, P. S. Defence Colony, New Delhi-110024.
w.e.f.-MHA portal ID – 2024030902794 dated 27/03/2024.