

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/ 228

DATED: 30/04/2024

To,

The President / Secretary
Manchahat CGHS Ltd.
Plot No-42, Sector-10, Dwarka,
New Delhi-110075.

Subject: - Renewal of Fire Safety Certificate in r/o Manchahat CGHS Ltd. Located at Plot No-42, Sector-10, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter No. Manchahat/CGHS/Fire/23-24/19, dated-09/03/2024 on the subject cited above. In this connection it is to inform to you that the above said residential building has been re-inspected by the officer concerned of this department on 16/04/2024 in the presence of Sh. Bhagwan Soni (Secretary) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found encroached & Trimming of trees/ encroachment must be removed to ensure the free movement of fire vehicles around the building.
2. Staircases found not clear at some places.
3. P.A. System found nonfunctional.
4. Exit signage's found removed at some places.
5. Communication system in lift car found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service
O/c
29/4/24

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.