

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/199
To

Dated: 30/4...../2024

The Principal,
MCD Primary Co-ed School,
PTS Colony, Malviya Nagar,
New Delhi 110017.

Sub: Regarding issuance of FSC in r/o MCD Primary Co-ed School, PTS Colony, Malviya Nagar, New Delhi 110017.

Sir,

This has reference to your Email dated 08/04/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.04.2024 in the presence of Ms Sushma Arora (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two staircase having width of 1.50 mtr & 1.20 mtr against the required width of 1.50 mtr each.
2. Overhead tank capacity 6,000 ltrs provided against the required capacity of 10,000 ltrs.
3. Exit signage not provided in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-02