

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2024/SZ/226
To

Dated:- 30/04/2024

The Executive Engineer (Parking Project)
Municipal Corporation of Delhi
Under Bhishan Pitamah Flyover, Sewa Nagar,
New Delhi 110003

Sub: - Regarding issuance of fire safety certificate in r/o M/s MICP at MCD Land Adjoining Adhchini village, Along towards Janta Flat, Aurobindo Marg, New Delhi

Sir,

This has reference to with letter No D/EE (Parking)/MCD/2024-25/03 dated 03/04/2024 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.04.2024 in the presence of Mr. Suraj (Side Incharge) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There are two staircases having width of 1.50 mtr each but the second staircase is found lock & key is not allowed.
2. The staircase communicated ground to terrace level is removed at 4th level.
3. First aid hose reel provided but found not working.
4. Automatic sprinkler system provided but found not working.
5. Internal hydrant provided but found not working.
6. Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM provided but found not working.
7. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten Signature]