

d/64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/NDZ/2024/ 152

Dated: 23/04/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Moti Mahal Restaurant located at 3704, Netaji Subhash Marg, Daryaganj, Delhi- 02.

Sir,

This has reference to online application ID No. 2024022302080 dated 31.03.2024 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.04.2024 in presence of Mr. Vinod Chadha (Owner) and it was observed that building is comprised of ground floor only and have been partially complied the shortcomings issued vide letter no. F6/DFS/MS/EH/NDZ/2024/15 dated 10.01.2024 except following which still exists:-

1. Smoke detectors provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 01123414000
012
ce - 12/4

Copy to:-

The Licensee,
M/s Moti Mahal Restaurant at 3704, Netaji Subhash Marg, Daryaganj, Delhi - 02.